

Borough of Paramus
Fire Prevention Bureau
1 Jockish Square
Paramus, New Jersey 07652
Tel: 201-265-2100 Ext: 2290
Fax: 201 265-5556
Email: Fireprevention@paramusborough.org

NEW JERSEY UNIFORM FIRE CODE

NEW JERSEY ADMINISTRATIVE CODE TITLE: 5

CHAPTER 70

TYPE 1 PERMIT

NJAC 5:70-2.7(a)3.

FEE: \$54.00

NJAC 5:70-2.7(a)3vi. Welding or Cutting Operation:

Welding or cutting operations except where the welding or cutting is performed in areas approved for welding by the fire official and are registered as a Type B life hazard use:

Jewelry Repair

Name: _____

Address: _____

Telephone: _____

Business Address: _____

Booth #: _____ (if applicable) 1922

After fee is paid and inspection is made by this office, a permit will be issued.

Requirements: As per New Jersey Uniform Fire Code N.J.A.C. 5:70-3.1(a)36.F-3606.1

1. One portable fire extinguisher having a rating of not less than 2-A:20-B:C shall be kept within 75' travel distance from the area where the torch is utilized.
2. Cylinders must be properly secured.
3. Propane cylinders shall not exceed 5 pounds LP-gas capacity

I hereby acknowledge that I have read the above, and all information given is correct, and I agree to abide by the above requirements.

Signature: _____ Date: _____

