

**Borough of Paramus
Fire Prevention Bureau
1 Jockish Square
Paramus, New Jersey 07652
Tel: 201-265-2100 Ext: 2290
Fax: 201 265-5556**

Email: Fireprevention@paramusborough.org

NEW JERSEY UNIFORM FIRE CODE

NEW JERSEY ADMINISTRATIVE CODE TITLE: 5
CHAPTER 70

TYPE 2 PERMIT

NJAC 5:70-2.9(c)2

FEE: \$214.00

NJAC 5:70-2.7(a)4viii.: The storage or retail sales of sparkling devices and novelties in any temporary or permanent structure, when the pyrotechnic content exceeds 125 pounds; as defined in Section 202, and shall comply with Section 5609, and NFPA 1124.

Name: _____

Address: _____

Telephone: _____

Retail Information:

Store Name: _____

Address: _____

Telephone: _____

Requirements:

1. Sparkling devices and novelties shall not be displayed within 5 feet of a public entrance
2. Portable fire extinguishers shall be provided within 75' travel distance and must have a 2-A:10-B-C rating.
3. Shelving and merchandise shall be no higher than 6 feet above the floor
4. Electrical wiring and equipment shall meet NFPA 70; the use of extension cords for display units shall be prohibited.
5. All sparkling devices and novelties shall have covered fuses so that the fuse cannot be touched by a person without unwrapping, tearing or puncturing the package. Open and/or damaged packages shall be removed from retail sales area.

I hereby acknowledge that I have read the above, and all information given is correct, and I agree to abide by the above requirements.

Signature: _____ Date: _____